

Questions and Answers
Hometown Store
Commerce # 53220-2321-08A
WDNR BRRTS # 03-41-004617

Q1 The monitoring well with the highest contaminant concentrations (MW-12) is immediately downgradient of the existing tanks. Are these tanks upgraded and have they been tested for tightness since 1994?

A1 According to the Department of Commerce's storage tank database, the four Underground Storage Tanks (UST) that remain on site meet the Federal requirements for upgraded UST. Commerce is unable to answer the issue of tightness testing. All four UST are equipped with automatic tank gauging for leak detection.